

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of approval constancy of performance 2831-CPR-S0017

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

'Crico' Hose Reels with Semi-Rigid Hose

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of:

Crico Engineering
Zuiddijk 10
8340 Damme
Belgium

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 671-1:2012

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 December 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

S. A. Colwell

Sarah Colwell, Certification Engineer, Fire Suppression

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 December 2019

Issue Date: 20 September 2023

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland**Approved Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-S0017**'Crico' Hose Reels with Semi-Rigid Hose**

The fire hose reels covered by this Certificate of constancy of performance placed on the market by Crico Engineering are identified below and must be installed in accordance with the manufacturer's installation instructions

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)
AQUASPRAY 20S	Manual, swinging arm, cabinet or wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	19	30
AQUASPRAY 30S	Manual, swinging arm, cabinet or wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	25	30
AQUAJET MP33	Manual, swinging arm, wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	33	30
AQUASPRAY 20F	Manual, fixed, wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	19	30
AQUASPRAY 30F	Manual, fixed, wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	25	30
AQUAJET MP25	Manual, swinging arm, wall mounted hose reel with semi-rigid hose and rotary operated jet/spray nozzle	25	30

S. A. Colwell

Sarah Colwell, Certification Engineer, Fire Suppression

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 December 2019

Issue Date: 20 September 2023

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie